

## **DECLARATION OF CONFORMITY**

According to Act No. 22/1997 Coll., as amended, and  $\S13$  of Government Regulation No. 163/2002 Coll., as amended

Manufacturer:

## HACO, spol. s r. o. Svobody 826/88 460 15 Liberec Company ID: 615 35 699 Production facility: as above

Declares at its sole responsibility that the following product:

•

## HVAC duct systems

Type/version: AL FLEXO pipe

Is in compliance with essential technical requirements for the product under Government Regulation No. 163/2002 Coll., as amended, which determines technical requirements for selected building products. The product is safe to use under the conditions of its intended application.

Product description and the scope of its use in building structures: AL FLEXO-type pipe is designed for air distribution in buildings, both for air supply and air extraction. The distribution system comprises a modular system, formed by air pipes, a pipe diameter adapter, hose clips, check valves, etc.

The pipe has a circular cross-section of different diameters, made of aluminium, semi-flexible and with an extensible longitudinally. The material is aluminium 80 microns thick, with a thermal resistance from 40°C to 250°C. Coupling is mechanical, using a hose clip or PVC a tape and ALU adhesive tape.

The application of the product and its technical specifications are defined in the product's technical data sheet describing its properties, installation and use.

The manufacturer has taken measures to ensure the compliance of the product with the technical documentation and essential requirements.

The product was assessed according to §8 of the above Government Regulation and Building Technical Certificate No. 090-052467 was issued based on this assessment on July 2<sup>nd</sup> 2021 in Prague by Technical and Test Institute for Construction Prague, s.p., Authorized Body No. 204, with its registered office at Prosecka 811/76a, 190 00 Prague 9 – Prosek.

In Liberec, on 02.07.2021

